

Water Service Availability Request & Certification

Property Located At:	East View Ave at Uxbridge St, Soutwest co Ave.	rner lot. Current address 25	7 East View
Plat: 11	Lot(s): 1177	Recorded Lot:	to the second of the second
	To Be Completed By Water Auth	nority	
Is Water Available?		Yes	No
Is a Water Main Extension Required?		Yes	No
Is a Service Connection Required?		Yes	No
Is an Easement Involved?		Yes	(1)
Is Proposed Water Service a Minimum of Ten (10') Feet from any Sewer Line?		Yes Unknown	Нө
	Locations Unknown by PW ter owns and maintains an 8 inch asbestos cen	nent water main running alo	ng Uxbridge
St. with an approximate	pressure of 38 psi. The current property on the	nis lot has an existing 3/4 in	ch service,
being supplied from an	8 inch asbestos cement water main running ale	ong East View Ave.	
Verified By:	Title: Supervisor of	T&D Date	: 4/15/2024

Please mail completed original request & certification to:

Providence Water Engineering Department 125 Dupont Drive Providence, Rhode Island 02907 401-521-6300, ext. 7102